

**CERTIFICATE OF APPROVAL  
No CS 5055**

This is to certify that, in accordance with  
STS200 General Requirements for Certification of Enhanced Security Products  
The undermentioned products of

**EUROBOND DOORS LTD**

**Wentloog Corporate Park, Wentloog, Cardiff, CF3 2ER  
Tel: 02920 361 111 Fax: 02920 362 222**

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

**CERTIFIED PRODUCT  
BR1 Steel Doorsets**

**TECHNICAL SCHEDULE  
STS202 - Requirements for  
burglary resistance of  
construction products**

| CLASSIFICATION        |                          |                                 |                   |
|-----------------------|--------------------------|---------------------------------|-------------------|
| Security              | Weather                  | Strength                        | Material Specific |
| <b>STS202<br/>BR1</b> | <b>BS6375-1<br/>800U</b> | <b>BS6375-2<br/>Medium Duty</b> | <b>NPD</b>        |

**NPD = No performance determined**

**Signed and sealed for and on behalf of Exova (UK) Limited trading as  
Warrington Certification**



**Paul Duggan  
Certification Manager**



Issued: 27<sup>th</sup> February 2015  
Reissued: 9<sup>th</sup> March 2018  
Valid to: 8<sup>th</sup> March 2023

Page 1 of 3



**CERTIFICATE No CS 5055  
EUROBOND DOORS LTD**

**Eurobond – BR1 Steel Doorsets**

1. This approval relates to the use of the above in providing a burglar resistance to STS 202 level BR1, a weather performance of 800U to BS6375-1:2009 and a mechanical strength performance of Medium Duty to BS6375-2:2009.
2. The doorsets are approved on the basis of:
  - i. Initial type testing against STS202, BS6375-1 & BS6375-2. Exova test reports WIL 338316, WIL 338319, WIL 339094 & WIL 340261.
  - ii. Audit testing at the frequency specified in STS 200 & STS 202 where relevant.
  - iii. A design appraisal against STS202 where relevant.
  - iv. Inspection and surveillance of factory production control at Wentloog Corporate Park, Wentloog Road, Cardiff CF3 2ER.
3. This approval is applicable to complete doorsets only.
4. This certification is designed to demonstrate compliance of the doorset specifically with STS202 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
5. This approval is applicable to single-leaf, unglazed, open-out doorsets at leaf dimensions up to those given in Table 1.
6. Approved hardware items are:
  - 4no. Cooke Brothers shrouded bearing hinge
  - Union Optimus 3 mortice deadlock with SLS escutcheon set
  - Union Optimus 3 mortice sashlock with SLS escutcheon set & Assa Abloy lever set
  - Union Optimus 3 emergency escape with SLS escutcheon set & Assa Abloy lever set
  - Assa Abloy Novel eurocylinder
  - Dorma overhead closer

For the full specification of the product please refer to the constructional specification that accompanies this certificate.

| Configuration               | Maximum door leaf width (mm) | Maximum door leaf height (mm) | Door leaf thickness (mm) |
|-----------------------------|------------------------------|-------------------------------|--------------------------|
| Open-out, single-leaf only. | 970                          | 2510                          | 44                       |

**Table 1. Permitted Door Leaf Dimensions**

**CERTIFICATE No CS 5055  
EUROBOND DOORS LTD**

**Eurobond – BR1 Steel Doorsets**

| Configuration | Maximum frame width (mm) | Maximum frame height (mm) |
|---------------|--------------------------|---------------------------|
| Single leaf   | 1000                     | 2550                      |

**Table 2. Permitted Frame Dimensions**

**Note:** Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTISECURE approval.

7. The doorsets shall be mechanically fixed to wall constructions as described in manufacturers approved installation instructions.
8. Labels to the EWCL design referencing CERTISECURE, STS202 BR1, Eurobond Doors, and CERTISECURE certificate No. CS 5055 shall be affixed to each door in the prescribed position.
9. This approval relates to on going production. The doorset and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTISECURE name and mark together with the CERTISECURE Certificate number and application where appropriate.

**Further Information**

Further information regarding the details contained in this report may be obtained from Eurobond Doors, Wentloog Corporate Park, Wentloog, Cardiff, CF3 2ER (Tel: 02920 361 111 Fax: 02920 362 222)

Further information regarding CERTISECURE certification and other approved products can be obtained from Exova Warrington Certification, Holmesfield Road, Warrington WA1 2DS (Tel: 01925 646777).