

**CERTIFICATE OF APPROVAL
No CS 5056**

This is to certify that, in accordance with
STS200 General Requirements for Certification of Enhanced Security Products
The undermentioned products of

EUROBOND DOORS LTD

**Wentloog Corporate Park, Wentloog, Cardiff, CF3 2ER
Tel: 02920 361 111 Fax: 02920 362 222**

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

**CERTIFIED PRODUCT
BR2 Steel Doorsets**

**TECHNICAL SCHEDULE
STS202 - Requirements for
burglary resistance of
construction products**

CLASSIFICATION			
Security	Weather	Strength	Material Specific
STS202 BR2	BS6375-1 800U	BS6375-2 Medium Duty	NPD

NPD = No performance determined

**Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification**



**Paul Duggan
Certification Manager**



Issued: 27th February 2015
Reissued: 9th March 2018
Valid to: 8th March 2023

**CERTIFICATE No CS 5056
EUROBOND DOORS LTD**

Eurobond – BR2 Steel Doorsets

1. This approval relates to the use of the above in providing a burglar resistance to STS 202 level BR2, a weather performance of 800U to BS6375-1:2009 and a mechanical strength performance of Medium Duty to BS6375-2:2009.
2. The doorsets are approved on the basis of:
 - i. Initial type testing against STS202, BS6375-1 & BS6375-2. Exova Warringtonfire test reports WIL 336780, WIL 338324, WIL 339093, WIL 339095 & WIL 343960.
 - ii. Audit testing at the frequency specified in STS 200 & STS 202 where relevant.
 - iii. A design appraisal against STS202 where relevant.
 - iv. Inspection and surveillance of factory production control at Wentloog Corporate Park, Wentloog Road, Cardiff CF3 2ER.
3. This approval is applicable to complete doorsets only.
4. This certification is designed to demonstrate compliance of the doorset specifically with STS202 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
5. This approval is applicable to single-leaf & double leaf, unglazed, open-out doorsets at leaf dimensions up to those given in Table 1.
6. Approved hardware items are:
 - 4no. Cooke Brothers shrouded bearing hinge
 - Surelock McGill Stirling locks
Surelock McGill Slimline lock
 - Surelock McGill barrel bolts to inactive leaf
 - Union rim cylinder with Surelock McGill cylinder guard
 - Dorma overhead closer

For the full specification of the product please refer to the constructional specification that accompanies this certificate.

Configuration	Maximum door leaf width (mm)	Maximum door leaf height (mm)	Door leaf thickness (mm)
Open-out, single-leaf.	970	2510	44
Open-out, double-leaf.	915	2510	44

Table 1. Permitted Door Leaf Dimensions

**CERTIFICATE No CS 5056
EUROBOND DOORS LTD**

Eurobond – BR2 Steel Doorsets

Configuration	Maximum frame width (mm)	Maximum frame height (mm)
Single leaf	1000	2550
Double leaf	1895	2550

Table 2. Permitted Frame Dimensions

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTISECURE approval.

7. The doorsets shall be mechanically fixed to wall constructions as described in manufacturers approved installation instructions.
8. Labels to the EWCL design referencing CERTISECURE, STS202 BR2, Eurobond Doors, and CERTISECURE certificate No. CS 5056 shall be affixed to each door in the prescribed position.
9. This approval relates to on going production. The doorset and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTISECURE name and mark together with the CERTISECURE Certificate number and application where appropriate.

Further Information

Further information regarding the details contained in this report may be obtained from Eurobond Doors, Wentloog Corporate Park, Wentloog, Cardiff, CF3 2ER (Tel: 02920 361 111 Fax: 02920 362 222)

Further information regarding CERTISECURE certification and other approved products can be obtained from Exova Warrington Certification, Holmesfield Road, Warrington WA1 2DS (Tel: 01925 646777).